

## WR/PG21-50M

Order No.: 1666867

The illustration shows the version WR/PG16-50M

<http://eshop.phoenixcontact.de/phoenix/treeViewClick.do?UID=1666867>Corrugated tube, for corrugated tube screw connection, packing  
volume 50 m, size Pg21

Commercial data	
GTIN (EAN)	4017918136512
Note	Made-to-order
sales group	D096
Pack	1 pcs.
Customs tariff	39173900
Weight/Piece	4.84 KG
Catalog page information	Page 556 (PC-2009)

**Product notes**WEEE/RoHS-compliant since:  
01/01/2003


<http://www.download.phoenixcontact.com>  
Please note that the data given here has been taken from the online catalog. For comprehensive information and data, please refer to the user documentation. The General Terms and Conditions of Use apply to Internet downloads.

**Technical data**

General data	
Pg screw connection	21
Material	PA
Inflammability class acc. to UL 94	HB
Ambient temperature (operation)	-40 °C ... 110 °C

## Diagrams/Drawings

### Dimensioned drawing




#### Assembly instructions for Pg21 corrugated pipe

a = Corrugated screw connection  
B = Corrugated pipe  
c = Opener

##### Installation note:

Cut the corrugated pipe in the groove to retain a round shape for insertion. The lighter seal (not depicted in the illustration) is positioned in the corrugated pipe screw connection below the safety latch. The darker outer seal (not depicted in the illustration) is placed over the corrugated pipe screw connection from outside. The corrugated pipe is then pushed as far as possible into the corrugated pipe screw connection and clicks into place. The screw connection is opened by placing the yellow corrugated pipe opener with force between the safety latch and the corrugated tube and the corrugated pipe is then pulled out.



#### Assembly instructions for M25 corrugated pipe

a = Corrugated screw connection  
b = Corrugated pipe  
c = Opener

##### Installation note:

Cut the corrugated pipe in the groove to retain a round shape for insertion. The lighter seal (not depicted in the illustration) is positioned in the corrugated pipe screw connection below the safety latch. The darker outer seal (not depicted in the illustration) is placed over the corrugated pipe screw connection from outside. The corrugated pipe is then pushed as far as possible into the corrugated pipe screw connection and clicks into place. The screw connection is opened by placing the yellow corrugated pipe opener with force between the safety latch and the corrugated tube and the corrugated pipe is then pulled out.

**Address**

PHOENIX CONTACT Inc., USA  
586 Fulling Mill Road  
Middletown, PA 17057, USA  
Phone (800) 888-7388  
Fax (717) 944-1625  
<http://www.phoenixcon.com>



© 2010 Phoenix Contact  
Technical modifications reserved;